

	Operand	Symbol	Symbolkommentar	Anzeigeformat	Statuswert	Steuerwert
1	// OUTPUT PARAMETERS EMGZ491					
2	// Slot 0					
3	DB4.DBD 28	"WRITE_PARAM".TENSION_MAX_OUTPUT	Analog output scaling	DEZ		L#2000000
4	DB4.DBX 32.0	"WRITE_PARAM".WRITE_TENSION_MAX_O	If set, the tension max output will be written to the EMGZ491	BOOL		false
5	DB4.DBB 33	"WRITE_PARAM".OUTPUT_FILTER_ON	Low Pass Filter Active of output	DEZ		1
6	DB4.DBX 34.0	"WRITE_PARAM".WRITE_OUTPUT_FILTER	If set, the output filter on will be written to the EMGZ491	BOOL		false
7	DB4.DBW 36	"WRITE_PARAM".CUTOFF_FREQU_OUTPU	Cutoff Frequency Low Pass Filter of output	DEZ		10
8	DB4.DBX 38.0	"WRITE_PARAM".WRITE_CUTOFF_FREQU	If set, the cutoff frequ output will be written to the EMGZ491	BOOL		false
9						