

FB3 - <offline>

"FMS_CYCLIC_FB"

Name:
Autor:
Zeitstempel Code:
Interface:
Längen (Baustein / Code / Daten):

Familie:
Version: 0.1
Bausteinversion: 2
17.01.2019 09:52:20
20.09.2012 14:35:00
00158 00066 00000

Name	Datentyp	Adresse	Anfangswert	Kommentar
IN		0.0		
OUT		0.0		
IN_OUT		0.0		
STAT		0.0		
TEMP		0.0		

Baustein: FB3

Netzwerk: 1 Status overload channel A

L	PEW	256			
T		"FMS_CYCLIC_DB".ACT_VAL_DIGIT	DB3.DBW0	--	Actual value in digits
L	PED	258			
T		"FMS_CYCLIC_DB".ACT_VAL_NEWTON	DB3.DBD2	--	Actual value in N
L	PED	262			
T		"FMS_CYCLIC_DB".ACT_VAL_POUND	DB3.DBD6	--	Actual value in lb
L	PED	266			
T		"FMS_CYCLIC_DB".ACT_VAL_CONF_UNIT	DB3.DBD10	--	Actual value in the configured unit
U	E	0.0			
=		"FMS_CYCLIC_DB".STATUS_OVERLOAD	DB3.DBX14.0	--	Status overload
U	E	0.1			
=		"FMS_CYCLIC_DB".STATUS_OUTPUT_OVERFLOW	DB3.DBX14.1	--	Status output overflow
U	E	0.2			
=		"FMS_CYCLIC_DB".STATUS_OUTPUT_UNDERFLOW	DB3.DBX14.2	--	Status output underflow